

COBB COUNTY SCHOOL DISTRICT
PROCUREMENT DEPARTMENT
6975 Cobb International Boulevard
Kennesaw, GA 30152

TO: All Prospective Vendors

DATE: August 28, 2009

SUBJECT: Addendum No. 3 to “RFP 35-09”

ADDENDUM: Please review Intercom Clarification, Flooring Clarification, and Site Survey Clarification (Under Special Terms & Conditions, Section 2.1.2).

Intercom Clarification – Under Low Voltage Requirements (Special Terms & Conditions, Section 8)

Vendor will be responsible to run a 4 conductor cable from each modular unit to the Intercom Control Panel in the school’s main office. Each run must have 10ft. of slack & labeled by unit.

Reference CCSD Design Standards for cable specifications.

Flooring Clarification – Special Terms & Conditions – General Information, Section 6

CCSD is looking for a solution similar to *flooring utilizing a poured lightweight concrete with fiberglass reinforcement or comparable, as currently being mandated in Florida schools.*

Site Survey Clarification - Special Terms & Conditions – 2.1.2

Section: Vendor’s response must include the following: *topographical survey with a proposed site plan, including vendor solution, architectural plans for the structure(s) that are verified & stamped by a licensed Architect/ Engineer and, which delineates utilities and all features that may affect modular installation.*

Clarification: Topographical survey with a proposed site plan, including vendor solution, architectural plans for the structure(s) that are verified & stamped by a licensed Architect/Engineer and, which delineates utilities and all features that may affect modular installation. Must be provided by Awarded Vendor.

Ginny Martin, CPPB
Procurement Services